

2" Sch. 40 conduit is **required** for all primary installations.

It is the member's responsibility to pick up any vault or pull box from our warehouse and install them on their property.

*(Warehouse locations listed on back panel)*

You must have a JOB NUMBER for our warehouse in order to pick up any vault or pull box.

Please reference your invoice or contact the service planner in your county to obtain the JOB NUMBER.

**Failure to follow these requirements will result in significant delays in your service installation.**



**Know what's below.  
Call before you dig.**

<b>⚠ WARNING</b>		
 <b>Hazardous voltage inside.</b> Can shock, burn, or cause death. Keep out. If open or unlocked, immediately call Owen Electric Cooperative 1-800-372-7612	<b>ENERGIZED ELECTRICAL EQUIPMENT</b>  Maintain 5 ft. clearance on this side and 5 ft. on all other sides from fences, shrubs, and structures.	<b>STOP!</b>  48 HOURS BEFORE YOU DIG CALL K.U.P.I. 1-800-752-6007



A Touchstone Energy<sup>®</sup> Cooperative

**Owenton Warehouse**  
8205 Hwy 127 N  
PO Box 400  
Owenton, KY 40359  
800-372-7612  
www.owenelectric.com

**Walton Warehouse**  
13179 Walton Verona Road  
Walton, KY 41094

*Owen Electric Cooperative is  
an equal opportunity provider.*

## Owen Electric Cooperative's Primary Underground Electric Service



This brochure provides the information you need to prepare for your primary underground electric installation.



Ditch shall be 42 inches deep minimum and free from rocks/sharp objects.




Install pull strings in all conduits



Sweep tight against pole

Any radius elbows used shall be 3 feet, 90 degree 2 inch sweeps.



Level both ways - Final grade.



Level with final grade

The pull box needs to be flush with the final grade.



Center opening

Install all conduits in the center of the opening in the vault.



Front

Face toward the road or the driveway.

- Ground elevation for the vaults/allow for final grade so the vault is still out of the ground at least 6 inches.
- Make sure the vault is level in both directions.